



SHORE TIE GROUND ELECTRICAL SAFETY PLEASE READ

Members,

Recent inspections have revealed that when connected to marina shore power, some vessel shore power cords are not making adequate electrical ground connection due to various factors including corrosion and poor cable/connector condition. Lack of proper shore power grounding is a serious electrical safety condition. To ensure your safety and prevent damage to your vessel, we are asking all wet-slip renters to disconnect from shore power and inspect shore power pedestals, cables, connectors, and on-board inlets for evidence of corrosion or other damage before Dec 14. After Dec 14, our maintenance team will conduct this inspection on the remaining slips, which will include temporary disconnection of the shore tie.

For effective preventive maintenance, all members should be disconnecting and inspecting connections at a minimum of once per year. We will include this action in your annual vessel seaworthiness check.

Please inform our Maintenance Supervisor, Irving Sherman at 321-494-7455, Tue - Sat, 9 am - 4 pm or via e-mail @ Irving.Sherman@us.af.mil when you intend to stop by, a marina member should be present in order to remove corrosion. Please e-mail Mr. Sherman if you would like our maintenance staff to check your shore tie for you.